


1 2 3 4 5 6 7 8 9 10



16	UPPER PLATE	HDPE
15	LOWER PLATE	HDPE
14	END CAP FOR SPINDLE CONNECTION	ASTM A216 WCB
13	SIDE GUIDE	
12	TOP SEAL SUPPORT	HDPE
11	OVER TRAVEL STOP	
10	STEM	STAINLESS STEEL EN 1.4401 (316)
09	TOP SEAL	
08	SIDE SEAL	EPDM RUBBER
07	FLUSH BOTTOM RUBBER SEAL	
06	THRUST NUT	LEADED GUN METAL BS EN-1982 LG2
05	BOTTOM SEAL RETAINER	
04	TOP SEAL RETAINER	
03	SIDE SEAL RETAINER	STAINLESS STEEL EN 1.4401 (316)
02	SHUTTER	
01	FRAME	
Sr.	DESCRIPTION	MATERIAL

**WATERFRONT FLUID CONTROLS**  
 MARITIME HOUSE (SUITE 8),  
 143 WOODVILLE ST, GLASGOW, G51 2RQ  
 WEB: www.waterfrontfc.co.uk  
 TEL: (44) 0141-445-3781  
 FAX: (44) 0141-445-5101



**TITLE:**  
 DETAILS OF STAINLESS STEEL FACE WALL MOUNTING, UPWARD  
 OPENING, SELF CONTAINED, NON-RISING SPINDLE, RESILIENT  
 SEATED, SLUICE GATE SUITABLE FOR 6M SEATING AND UNSEATING  
 WATER HEAD. GATE SIZE 914 SQ.

**DRAWING NUMBER:**  
 JE/SG/GAC/FBF/10681-A

**REV NUMBER:** R3

**MATERIAL:** SEE MATERIAL NOTES

**SHEET NUMBER:** 1 OF 1

**NOTES :-**  
 (1) ALLOWABLE DEVIATION FOR DIMENSIONS WITHOUT SPECIFIED TOLERANCES TO BE AS PER IS : 2768.  
 (2) ALL FASTENERS (NUTS, BOLTS & WASHERS) FOR GATE ASSEMBLY TO BE OF STAINLESS STEEL EN 1.4401 (316)  
 (3) ALL STAINLESS STEEL FABRICATED PARTS TO BE BLAST CLEANED TO REMOVE SURFACE CONTAMINATION AND THEREAFTER PICKLED AND PASSIVATED  
 (4) ADHESIVE CAPSULE/CHEMICAL CAPSULE & CHEMICAL ANCHOR FASTENERS TO BE ARRANGED BY CLIENT  
 (5) APPROX. OUTER DIMENSIONS OF GATE ASSLY IS 1134 x 2214 x 135mm  
 (6) REFER DRG. NO. JE/SG/GEN/1491-R1 FOR SECTIONAL DETAILS.

J	R3	25.01.24	SHUTTER MODIFIED	BP	SJ
	R2	07.03.20	FRAME FASTENER QTY. 14 WAS 12	GDC	SA
	R1	26.02.20	BS CAP MODIFIED.	SJ	SA
	REV	DATE	DESCRIPTION	REVSD. BY	CHKD. BY

DRAWN BY: R.Y.	PROJECT: ----	GENERAL TOLERANCES: MACHINING: ±0.2mm DIMMS: <1000mm ±1.5mm DIMMS: >1000mm ±2.0mm	FIRST ANGLE PROJECTION	DO NOT SCALE FROM THIS DRAWING
CHECKED BY: S.A.	CLIENT NAME: ----	THIS DOCUMENT IS COPYRIGHT AND IS THE PROPERTY OF WATERFRONT FLUID CONTROLS. IT MUST NOT BE COPIED OR DISCLOSED TO A THIRD PARTY, INCLUDING MANUFACTURE OF THE PRODUCT SHOWN THEREIN, WITHOUT THE WRITTEN CONSENT OF THE COMPANY.		
APPROVED BY: N.K.V.	LOCATION: ----	© 2009 WATERFRONT FLUID CONTROLS		

1 2 3 4 5 6 7 8 9 10